

**ANDHRA PRADESH STATE LOAD DESPATCH CENTRE**

**From**  
Chief Engineer,  
APSLDC,  
Vidyut Soudha,  
Gunadala, Vijayawada- 520 004.

**To**  
The Executive Director,  
RAC,PLG,EA & IPC,  
APSPDCL,19-13-65/A,  
Vidyut Nilayam, Srinivasapuram,Tirupati.

The Chief General Manager,  
RAC,PPA & Solar Energy,  
3<sup>rd</sup> Floor, APEPDCL,  
Corporate office,P&T Colony,  
Sethammadhara, Visakhapatnam-530013.

The Chief General Manager,  
RAC, APCPDCL, Corporate office,  
ITI Road, Vijayawada.

**Lr. No. CE/SLDC/SE/GO/DEPPMO/DEE2/AEE-PP/F.Avail/D. No. 798/25, Dt. 21.10.2025**

**Sir,**


**Sub:** APSLDC-Provisional Percentage cumulative availabilities/Capacity Index of APGENCO, APPDCL, HNPCL thermal Power stations and APGENCO Hydel Stations up to the month of Sep 2025 for FY2025-26 Communicated- Reg.

\* \* \* \* \*

The provisional percentage cumulative availabilities/Capacity Index of APGENCO ,APPDCL Thermal stations and APGENCO Hydel stations up to the month of Sep 2025 for FY 2025-26 are attached herewith.

Encl: As above.

Yours faithfully,

  
**Chief Engineer/APSLDC (FAC)**

Copy Communicated to CGM/Commercial/APTRANSCO/Vidyut Soudha/Vijayawada.

Copy Communicated to the Chief Engineer/Commercial/APGENCO/Vidyut Soudha/Vijayawada.


Copy Communicated to CGM/APPDCL/2<sup>nd</sup> Floor/APPCC Building /Vidyut Soudha/Vijayawada.

→ Copy Communicated to the Chief General Manager/Power Purchase/APPCC/Vidyut Soudha/Vijayawada.

Provisional Percentage availabilities/Capacity Index of APGENCO Thermal and Hydel stations for the Year 2025-26

Station/Month	Thermal Stations									Hydel stations								
	Dr.MVR RTPP Stg-I	Dr.MVR RTPP Stg-II	Dr.MVR RTPP Stg-III	Dr.MVR RTPP Stg-IV	Dr. NTTPS Stg- I TO III	Dr. NTTPS Stg -IV	Dr. NTTPS Stg -V	K.Patnam, Stage- I (against 1600MW)	K.Patnam, Stage-II	HNPCL	SSRB	Lower Sileru	Upper Sileru	Donkarayi	NSRC	Pennahobi lam	Chettipeta	NSRTail Pond
<b>Apr-25</b>	63.25	92.75	87.14	78.34	80.48	92.44	64.77	62.64	70.80	45.58	100.00	100.00	100.00	100.00	NC	NC	100.00	NC
<b>May-25</b>	62.94	76.05	80.88	68.32	70.53	87.89	18.47	58.89	83.57	45.79	100.00	100.00	100.00	100.00	NC	NC	101.00	NC
<b>Jun-25</b>	64.69	88.95	85.29	67.33	67.61	90.69	68.87	62.86	7.28	69.69	96.31	100.00	100.00	100.00	NC	NC	66.67	100.00
<b>Jul-25</b>	83.35	88.59	85.62	63.62	62.13	17.79	58.45	55.27	76.28	83.97	98.73	100.00	100.00	100.00	100.00	NC	75.27	99.77
<b>Aug-25</b>	84.45	90.52	84.44	71.56	70.51	63.77	61.44	55.54	78.71	90.20	97.22	100.00	100.00	100.00	100.00	NC	100.00	100.00
<b>Sep-25</b>	73.12	86.62	83.87	71.81	60.35	79.19	43.33	59.81	68.45	61.48	100.00	100.00	100.00	100.00	100.00	NC	100.00	99.38
Cumulative up to Sep 2025 for FY 2025-26	<b>72.05</b>	<b>87.21</b>	<b>84.52</b>	<b>70.13</b>	<b>68.59</b>	<b>71.71</b>	<b>52.45</b>	<b>58.15</b>	<b>64.47</b>	<b>66.24</b>	<b>98.35</b>	<b>100.00</b>	<b>100.00</b>	<b>100.00</b>	<b>100.00</b>	<b>NC</b>	<b>86.20</b>	<b>99.73</b>

Note: NC indicates not considered for calculation of capacity index as there is no water.

  
**CHIEF ENGINEER**  
**APSLDC, VIDYUT SOUDHA**  
**VIJAYAWADA**

**ANDHRA PRADESH STATE LOAD DESPATCH CENTRE**

**From**  
Chief Engineer,  
APSLDC,  
Vidyut Soudha,  
Gunadala, Vijayawada- 520 004.

**To**  
The Executive Director,  
RAC,PLG,EA & IPC,  
APSPDCL,19-13-65/A,  
Vidyut Nilayam, Srinivasapuram,Tirupati.

The Chief General Manager,  
RAC,PPA & Solar Energy,  
3rd Floor,APEPDCL,  
Corporate office,P&T Colony,  
Sethammadhara,Visakhapatnam-530013.

The Chief General Manager,  
APCPDCL,Corporate office,  
ITI Road,Vijayawada.

**Lr. No. CE/SLDC/SE/GO/DEPPMO/DEE2/F.Avail/D.No.920/25, Dt/2.12.2025**

**Sir,**

**Sub:** APSLDC-Provisional cumulative Percentage availabilities of Central Generating Stations (CGS) up to the month of Nov-2025 for FY 2025-26 Communicated- Reg.

\* \* \* \* \*

The Provisional Cumulative Percentage availabilities of Central Generating Stations (CGS) as declared by SRPC in their website up to the month of Nov 2025 are attached herewith. Further, it is to inform that the availabilities of CGS station are available in the SRPC website (<https://www.srpc.kar.nic.in>) under Regional Energy Account (REA) and may be downloaded from time to time.

Encl: As above.

Yours faithfully,



**Chief Engineer/APSLDC**

→ Copy Communicated to CGM/Commercial/APTRANSCO/Vidyut Soudha/Vijayawada.  
Copy Communicated to CGM/Legal & Power Purchase/APPCC/Vidyut Soudha/Vijayawada.

# 1a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

## April-2025, Peak Hours:

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month April, 2025	Up to The Month 2025-26	For The Month April, 2025	Up to The Month 2025-26
NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	97.443	97.443	97.444	97.444
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	98.333	98.333	98.594	98.594
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	100	100	100	100
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	97.513	97.513	97.133	97.133
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	99.819	99.819	99.985	99.985
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	94.785	94.785	95.066	95.066
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	87.465	87.465	87.804	87.804
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	93.343	93.343	94.515	94.515
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=83%)	29.933	29.933	30.902	30.902
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	38.884	38.884	39.529	39.529
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	82.668	82.668	83.335	83.335
NLC TS 2 Expn (I.C=500,NAux=12.5%, NPAF=70%,NPLF=85%)	4.186	4.186	4.237	4.237
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	93.261	93.261	92.729	92.729
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	89.234	89.234	89.528	89.528

\* \_\_\_ Note:Naux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12

# 1a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

May-2025, Peak Hours:06:00 to 08:00 Hrs and 18:30 to 20:30 Hrs

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month May, 2025	Up to The Month 2025-26	For The Month May, 2025	Up to The Month 2025-26
NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	98.381	97.919	98.179	97.818
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	99.726	99.041	98.884	98.741
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	99.833	99.915	99.923	99.961
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	100	98.777	100	98.59
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	99.189	99.499	99.667	99.824
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	97.354	96.09	97.586	96.347
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	98.677	93.163	98.434	93.206
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	99.855	96.652	99.862	97.232
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=83%)	21.76	25.78	22.338	26.55
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	26.164	32.419	27.112	33.219
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	75.244	78.895	77.125	80.179
NLC TS 2 Expn (I.C=500,NAux=12.5%,NPAF=70%,NPLF=85%)	26.692	15.623	27.429	16.023
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	48.434	70.48	48.089	70.043
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	81.461	85.284	81.595	85.497

\* Note:NAux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12

# 1a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

June-2025, Peak Hours:06:00 to 08:00 Hrs and 18:30 to 20:30 Hrs

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month June, 2025	Up to The Month 2025-26	For The Month June, 2025	Up to The Month 2025-26
NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	90.573	95.497	92.076	95.925
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	100	99.357	100	99.156
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	85.571	95.186	85.776	95.285
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	70.841	89.567	69.695	89.064
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	98.499	99.169	98.312	99.325
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	100	97.379	100	97.551
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	98.292	94.854	97.999	94.786
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	91.015	94.794	91.039	95.191
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=93%)	67.806	39.634	70.843	41.152
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	32.342	32.394	33.656	33.363
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	72.368	76.743	76.139	78.847
NLC TS 2 Expn (I.C=500,NAux=12.5%,NPAF=70%,NPLF=85%)	27.871	19.661	27.788	19.902
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	100	80.212	100	79.919
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	73.304	81.334	73.041	81.391

\* Note:NAux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12

# 1a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

July-2025, Peak Hours:06:00 to 08:00 Hrs and 18:30 to 20:30 Hrs

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month July, 2025	Up to The Month 2025-26	For The Month July, 2025	Up to The Month 2025-26
NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	81.611	91.969	81.872	92.354
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	100	99.521	99.637	99.278
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	77.342	90.652	77.331	90.723
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	55.239	80.844	55.314	80.488
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	96.687	98.541	96.645	98.647
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	97.302	97.36	97.54	97.548
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	75.174	89.853	74.985	89.755
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	47.058	82.664	46.871	82.913
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=83%)	34.646	38.367	37.457	40.213
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	33.982	32.797	36.4	34.135
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	74.256	76.111	80.66	79.308
NLC TS 2 Expn (I.C=500,NAux=12.5%, NPAF=70%,NPLF=85%)	22.763	20.449	22.723	20.618
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	97.581	84.625	97.66	84.427
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	44.642	72.011	44.878	72.113

\* \_\_ Note:Naux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12

# 1a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

August-2025, Peak Hours:06:00 to 08:00 Hrs and 18:30 to 20:30 Hrs

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month August, 2025	Up to The Month 2025-26	For The Month August, 2025	Up to The Month 2025-26
NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	71.219	87.765	75.251	88.889
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	100	99.618	100	99.425
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	88.754	90.267	89.493	90.473
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	92.179	83.141	95.64	83.558
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	94.272	97.679	96.384	98.19
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	49.145	87.591	63.979	90.747
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	77.347	87.319	94.29	90.673
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	92.109	84.578	92.447	84.845
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=83%)	34.143	39.489	37.364	41.438
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	44.558	36.684	48.97	38.566
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	61.333	73.117	67.832	76.983
NLC TS 2 Expn (I.C=500,NAux=12.5%,NPAF=70%,NPLF=85%)	48.373	26.107	48.747	26.318
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	96.754	87.083	96.689	86.911
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	62.731	69.68	63.344	69.529

\* \_\_ Note:Naux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12

# 1a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

September-2025, Peak Hours:06:00 to 08:00 Hrs and 19:00 to 21:00 Hrs

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month September, 2025	Up to The Month 2025-26	For The Month September, 2025	Up to The Month 2025-26
NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	62.215	83.576	67.926	85.452
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	84.678	97.169	89.533	97.803
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	70.058	86.954	70.272	87.162
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	90.943	84.419	92.976	85.101
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	87.292	95.98	88.629	96.627
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	74.76	85.487	77.521	88.578
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	85.726	87.058	92.606	90.99
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	97.644	86.72	97.988	86.999
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=83%)	44.516	40.307	47.584	42.426
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	49.039	38.747	52.496	40.883
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	33.001	66.541	37.446	70.501
NLC TS 2 Expn (I.C=500,NAux=12.5%,NPAF=70%,NPLF=85%)	68.509	33.058	68.575	33.245
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	100	89.2	100	89.057
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	81.303	71.592	81.916	71.57

\* Note:NAux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12

# 1a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

October-2025, Peak Hours:06:00 to 08:00 Hrs and 18:00 to 20:00 Hrs

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month October, 2025	Up to The Month 2025-26	For The Month October, 2025	Up to The Month 2025-26
NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	96.05	85.383	96.619	87.07
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	93.548	96.644	93.145	97.128
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	85.634	86.763	85.377	86.903
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	95.035	85.95	95.079	86.54
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	94.097	95.708	93.75	96.211
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	100	87.59	100	90.233
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	94.504	88.137	94.391	91.483
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	97.849	88.332	98.197	88.621
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=83%)	38.042	39.965	38.615	41.863
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	51.511	40.603	52.824	42.627
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	37.768	62.373	37.357	65.7
NLC TS 2 Expn (I.C=500,NAux=12.5%, NPAF=70%,NPLF=85%)	57.347	36.577	56.407	36.6
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	88.71	89.129	87.804	88.876
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	80.45	72.875	80.27	72.832

\* Note:Naux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12

## a. Plant Availability Factor of Inter State Generating Stations for the FY 2025-26

**November-2025, Peak Hours:07:00 to 08:00 Hrs and 17:00 to 20:00 Hrs**

ISGS	Plant Availability Factor (In Percentage)			
	Peak hours		Off Peak Hours	
	For The Month November, 2025	Up to The Month 2025-26	For The Month November, 2025	Up to The Month 2025-26
	NTPC RSTPS Stage 1 & 2 (I.C=2100,NAux=6.68%,NPAF=83%,NPLF=83%)	86.353	85.502	86.667
NTPC RSTPS Stage 3 (I.C=500,NAux=5.75%,NPAF=NPLF=85%)	87.5	95.52	88.777	96.102
NTPC Talcher STPS Stage 2 (I.C=2000,NAux=5.75%,NPAF=NPLF=85%)	95.734	87.866	95.675	87.982
NTPC Simhadri STPS Stage 2 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	99.375	87.594	99.892	88.175
NTPC Simhadri STPS Stage 1 (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)*	82.548	94.093	82.897	94.577
NTPC Kudgi STPS Stage 1 (I.C=2400,NAux=5.75%,NPAF=NPLF=85%)*	99.945	89.109	99.847	91.415
NTPC Telangana STPS (I.C=1600,NAux=5.75%,NPAF=NPLF=85%)*	82.303	87.419	83.522	90.504
NTECL Vallur STPS (I.C=1500,NAux=5.75%,NPAF=NPLF=85%)	96.845	89.379	97.918	89.764
NLC TS II Stage 1 (I.C=630,NAux=10%,NPAF=80%,NPLF=83%)	60.473	42.602	61.309	44.397
NLC TS II Stage 2 (I.C=840,NAux=10%,NPAF=80%,NPLF=85%)	51.431	41.811	52.403	43.718
NLC TS I Expn (I.C=420,NAux=9%,NPAF=NPLF=85%)	57.731	61.802	56.083	64.518
NLC TS 2 Expn (I.C=500,NAux=12.5%, NPAF=70%,NPLF=85%)	40.749	37.09	41.587	37.214
NTPL (I.C=1000,NAux=5.25%,NPAF=NPLF=85%)	82.073	88.262	82.764	88.124
NNTPP (I.C=1000,NAux=5.75%,NPAF=80%,NPLF=85%)	65.11	71.921	66.37	72.041

\* \_\_ Note:Naux has been modified for Telangana STPS, Simhadri STPS stage-1, Simhadri STPS Stage-2 and Kudgi STPS Stage-1 and is available at Table 12