

Revised on 29.03.2014

Technical Specification of
33KV 24V DC PTR HV VCBs WITH DIFFERENTIAL
PROTECTION WITH CONTROL & RELAY PANEL
AND CTs OF RATIO 400-200-100/1-1-1A

I. SCOPE :

This specification covers the manufacture, assembly, supply and delivery at Destination stores of 33 KV (Vacuum) Out Door porcelain clad pad type circuit breakers including current transformers, meters, relays and control panels for outdoor installations. The power system is with neutral solidly earthed. The equipment shall be guaranteed for 5 years.

II. APPLICABLE STANDARDS:

Unless otherwise modified in this specification, the Circuit Breakers, Current Transformers etc. shall comply with the following Standards with latest amendments.

IS	13118/1991 – High Voltage A.C. Circuit Breakers.
IEC	62271-100/2008 – Circuit Breakers.
IS	2705 (Part I to IV/1992) – Current Transformers.
IS	2099/1986 – Bushings for Alternating Voltages.
IS	13010/2003, IS 13779/1999 – Energy Meters.
IS	3231/1986 & 87 – Relays.
IS	1248/2003 – Ammeters & Voltmeters.
IS	13947/(Pt-1993 – Degree of protection provided b y Enclosures.

III. CLIMATIC CONDITIONS:

The climatic conditions under which the equipment shall operate satisfactorily are as indicated at clause No. 22 of General and Financial terms and conditions for supply of materials.

IV. PRINCIPAL PARAMETERS :

1. CIRCUIT BREAKERS :

- | | | |
|--------|--|---|
| 1.1. | Nominal System Voltage | : 33KV |
| 1.2 | Type | : Vacuum porcelain clad |
| 1.3 | Service | : ---- out door --- |
| 1.4 | No. of Poles/Phases | : ---- THREE --- |
| 1.5 | Highest System Voltage | : 36KV |
| 1.6 | Rated Frequency | : ----- 50 Hz ----- |
| 1.7 | System of earthing | : ---- Neutral solidly grounded ---- |
| 1.8 | Insulation level | : |
| 1.8.1. | Lightening Impulse withstand Voltage : 170 KV peak | |
| 1.8.2 | One minute power frequency withstand voltage. | : 70 KV (rms) |
| 1.8.3 | Power frequency withstand : | --- -2 KV (rms) ---/1 minute voltage on Auxiliary circuit |

Note: 1. The maximum power consumption for closing and tripping coils shall not exceed 200 W.

2. Please note that the above insulation levels supply at the reference conditions of temperature, pressure and humidity specified below :

- Temperature : 20 degree C.
 Pressure : 1013 millibars
 Humidity : 11 g/m³
- 1.9 Rated Thermal Current : 1250 A
- 1.10. Rated short circuit breaking current :
- 1.10.1. Symmetrical : 25 KA/3 Sec.**
- 1.10.2. Asymmetrical : As per IS : 13118/1991 or IEC – 62271-100/2008
- 1.11. Rating making capacity : 2.50 times Rated short circuit breaking Current (Symmetrical)
- 1.12. Rated short time withstand Current for 3 Sec. : 25 KA
- 1.13. Total break time : **60 m sec (max)**
- 1.14. Bushing Insulator
 Creepage distance : Not less than 900 mm/ As per IS
- 1.15. Mounting : --- Steel Structure --- (GI)
- 1.16. Rated Operating sequence : --- O-0.3 Sec. – CO– 3 Min – CO.
- 1.17. Operating Mechanism : Motor operated/ Manual spring Charged. The standard DC Voltage for the operating devices shall be 24V DC. Operating Voltage for motor spring charging mechanism shall be 250V with +/- 20%, DC/AC single phase. Normally the breaker shall be operated by Power and there shall be provision for manual operation.
- 1.18. Terminal Connector :
- 1.18.1. Material : --- Aluminium ---
- 1.18.2. Suitable for : Panther ACSR
- 1.19. Limits of temperature : The limits of temperature shall be in accordance with. IS : 13118/IEC- 62271-100/2008.
- 1.20. Requirement of Simultaneity of Poles : The maximum difference between instants of contact touching during closing and the maximum difference between the instant of contacts separation during opening between 3 poles shall not exceed one half cycle of the rated frequency. The Breaker shall be open and close simultaneously on all three phases for fault on any phase and or all the phases.
- 1.21. Protection : The Breaker shall be provided with
 (1) 3 Nos. Over Current (O/C) and
 (2) One Earth Fault (1 E/L) IDMT relays.
 3) Anti pumping relay
 4) DC Supervision relay
 5) Trip Circuit supervision relay
 6) Master trip relay (self Reset Type)
 7) Restricted earth fault relay
 8) Numerical Differential relay for Differential protection.

Note: The Numerical relays shall preferably be self powered with high set features with IDMT 1.3 Sec. Over current Relay settings ranging from 5% to 200% in steps of 1% and earth fault relay settings ranging from 5% to 80% in steps of 1%.

Settings for high set instantaneous elements for relays of 11KV Feeder VCBs shall be as follows.

High Set Instantaneous feature :

Over current 50% to 2000% in steps of 5% for 24V DC

Earth Fault 50% to 2000% in steps of 5% for 24V DC

Over current, earth fault time setting start from 0.01 to 1Sec in steps of 0.01Sec The relays shall have facility of minimum 5 Nos. fault tripping data such as 1.fault magnitude 2.Date and time of occurrence 3.Flag indication

“The over current relays shall be Numerical draw out type and all other mechanical relays are of non-draw out type”.

The over current relays should be of reputed make with IDMT characteristics and also with high instantaneous elements for high fault currents and shall comply with IS 3231. The accuracy class of relays shall be clearly specified.

Numerical differential relay shall have all necessary features for protection of Power transformer which include inrush currents and harmonic currents blocking settings.

- | | | |
|-----------------------|---|--|
| 1.22 | : | Auxiliary Power Supply |
| 1.22.1 A.C. Supply | : | 230 V \pm 20% (Phase to neutral),
3 phase, 50 HZ \pm 5%,
Effectively earthed system. |
| 1.22.2 D.C. Supply | : | 24V \pm 20%, 2 wire ungrounded system. |
| 1.22.3. Supply point: | | |
| 1.22.3.1 | : | Auxiliary power supplies listed above will be made available to each circuit breaker as below : |
| A.C. Supply | : | Single Feeder |
| D.C. Supply | : | Single feeder |
| 1.22.3.2 | | M.C.B. shall be provided at the circuit breaker for each Incoming A.C. Supply. For D.C. supply double pole M.C.B. shall be provided. (with different colours for each identification).The rating of MCBs shall be 20A. |

2. CURRENT TRANSFORMERS : 33 KV

- | | | | |
|--------|--|---|---|
| 2.1 | Rated voltage | : | 33 KV |
| 2.2. | Type | : | --- Single phase outdoor live tank oil Cooled Vacuum impregnated type – |
| 2.3. | Earthing | : | --- Solidly earthed --- |
| 2.4 | Insulation level | : | |
| 2.4.1. | Nominal system voltage | : | 33 KV |
| 2.4.2. | Highest system voltage | : | 36 KV |
| 2.4.3. | Lighting Impulse withstand voltage | : | 170 KV |
| 2.4.4. | One minute power frequency Withstand voltage | : | |
| (a) | Primary (HV) | : | 70 KV |
| (b) | Secondary (LV) | : | 3 KV |

2.5.	Frequency	:	--- 50 Hz ---
2.6.	Transformation ratio	:	400-200-100/1-1-1A
2.7	Rated secondary current (Amp)	:	
	i) Core I (Protection)	:	1
	ii) Core II (Metering)	:	1
	iii) Core III (Class-PS)	:	1A
	(Differential Protection)		
2.8	Rated output (VA)	:	
	i) Protection	:	15 VA
	ii) Metering	:	5 VA
	iii) Differential		
2.9	Class of accuracy :		
2.9.1.i)	Protection (Core I)	:	5P10
2.9.1.ii)	Metering (Core II)	:	0.2S
2.9.2.iii)	Diff. Protection (Core III)	:	PS
	a) Maximum Knee point Voltage Requirement	:	-- 40 I (R _{ct} +10) --- I = Rated current of CT.
	b) Maximum Excitation current	:	\leq (less than or equal to) 30mA at 0.25 V _k
2.10	Short time thermal current And its duration	:	25KA/3 Sec The short time thermal current should Suit the breaker rupturing capacity and Duration to suit the maximum tripping Time.
2.11.	Accuracy Limit factor	:	--- 10 for protective core ---
2.12.	Class of Insulation	:	Immersed in new insulating oil.
2.12.1	Limit of Temp. Rise (Max)	:	55 Degree C
2.13	Rated Continuous Thermal Current:		1250 A

NOTE : The CTs shall be live tank outdoor type and shall be offered with first filling of Oil. The Oil shall conform to the latest IS 335.

TECHNICAL REQUIREMENTS :

I. CIRCUIT BREAKERS

1.1 DESIGN CRITERIA

The equipment will be used in High Voltage system having characteristics as listed in the specification.

The equipment will be installed outdoor in hot, humid and tropical atmosphere.

All equipment, accessories and wiring shall have tropical protection, involving special treatment of metal and insulation against fungus, insects and corrosion.

The maximum temperature in any part of the equipment at specified rating shall not exceed the permissible limits as stipulated in the relevant standards.

The equipment shall be capable of withstanding the dynamic and thermal stresses of listed short circuit current without any damage or deterioration.

The safety clearances of all live parts of the equipment shall be as per relevant standards.

The breaker shall be of M2 class (10,000 operations).

1.2 TYPE AND DUTY :

The circuit breaker shall be outdoor, 3-pole, vacuum type having internal isolation without any sequential interlock.

In the event of order, the tenderer have to offer at least one breaker out of the offered lot in first inspection for testing in respect of Temperature rise test and mechanical endurance test of 10,000 Mechanical operations (M2 Class) in presence of purchaser representative as an acceptance test.

The duty of the circuit breaker shall involve satisfactory interruption of short circuit currents as listed in the clause-IV (Principal Parameters).

The breaker shall be capable of interruption of reactive current (lagging/leading) without under/over voltage.

1.3 CONSTRUCTION FEATURES :

1.3.1 GENERAL ARRANGEMENTS :

The circuit breaker shall have fixed type construction consisting three single identical poles, complete with a gang operated mechanism for specified duty. The interrupters shall be enclosed in a sealed porcelain housing conforming to protection to IS:13947 (Part-1) equivalent to IP-65 protection (IS:2147). All three poles of circuit breaker shall be linked together electrically / mechanically to ensure simultaneous closing/tripping of all poles.

The trip free operating mechanism, 3 phase inter connection links shall be completely accommodated in the base. There shall be sufficient clearance between live parts of the circuit breakers and the ground. The circuit breaker shall be complete with operating mechanism, other accessories/materials to ensure complete assembly and proper functioning. The current transformers shall be externally mounted on the supporting structure integrated with circuit Breaker structure. Terminal connectors suitable for Panther ACSR conductor for 33 KV should be supplied for Circuit Breakers and CTs. The circuit breaker shall be provided with proper standard earthing and with terminal earth bar for earthing connection. Suitable interconnection cable from breaker terminal, CTs terminal to control relay panel is 2.5 Sq.mm. PVC copper control cable (un-armored) are to be provided.

Neither the circuit breaker nor any part of the switchgear or its supporting structures shall be permanently strained due to vibration etc. when making or breaking the rated short circuit currents.

The details of any device incorporated in the circuit breakers to limit or control the rate of re striking voltage across the circuit breaking contacts shall be stated.

The vacuum interrupter assembly used in the circuit breakers shall be interchangeable with indigenously available vacuum interrupters (make and type shall be mentioned).

All metal enclosures shall be fabricated from minimum 2.5mm CRCA steel sheet free from all surface defects. The panel shall have sufficient structural re-enforcement to ensure a plain surface to limit vibration and to provide rigidity during dispatch and installation.

1.3.2 MAIN CONTACTS AND ARC QUENCHING CHAMBER :

The main contacts shall have adequate area and contact pressure for carrying rated continuous and short time current without excessive heating liable to cause pitting and welding.

The tips of the arcing and main contacts shall be special copper-Chromium alloy.

The contacts that are adjustable to allow for wear, shall be easily replaceable and shall have minimum movable part and adjustments. The arc-quenching device shall be of robust construction and shall not require any critical adjustment. The devices shall be easily accessible and removable for access to the breaker contacts.

Flexible laminations shall be of electrolytic copper. The ends of the laminations shall be solidified with hot pressed /electro fusion/electro solidification method to ensure good electrical contacts and achieve minimum contact resistance.

1.3.3 INTERLOCK :

All electrical and mechanical interlocks which are necessary for safe and satisfactory operation of the circuit breaker shall be furnished.

1.3.4 AUXILIARY CONTACTS :

Each breaker shall be provided with 4 normally open and 4 normally closed electrically separate spare auxiliary contacts in addition to those required for its own operation and indication exclusively for purchaser's use.

The auxiliary contacts shall be rated for 10A for AC and 10A for DC.

Note : 1. 1no Spare tripping coil and 1no closing coil shall be clamped in the Breaker.

2. Spring charging multiplier with 2 NO + 2NC shall be available and shall

be wired to the spare terminal blocks.

3. Auxiliary switch contact multiplier shall also be incorporated in the control panel and shall be wired to the spare terminal blocks.

1.3.5 INSULATORS :

Bushing insulators for circuit Breakers shall comply with IS2099-1986 specification for High Voltage porcelain bushings.

Insulators shall be wet process porcelain, brown glazed and free from all blemishes. Ferrous metal parts and hardware shall be hot-dip galvanised.

Insulators shall have adequate mechanical strength and rigidity to withstand the duty involved.

When operated at maximum system voltage, there shall be no electrical discharge. Shielding rings, if necessary, shall be provided. Insulation shall be coordinated with basic impulse level of the system. The creepage distance shall correspond to heavily polluted atmosphere.

1.4. OPERATING MECHANISM:

The operating mechanism shall be motor operated and manual operated for spring closing mechanism with trip free features complete with shut trip coils. All three poles of the breaker shall operate simultaneously. It shall operate in principle in such a way that the closing springs after each closing operation, are automatically charged by the motor and locked in the charged position by a latch. Means shall be provided to charge the springs manually also. Provision shall be made for the slow closing of the VCB irrespective of spring charge position.

The contact loading spring shall be designed in such a way that the closing stroke be completed and the opening stroke is commenced only from fully closed position. All the breakers shall be suitable for manual operation as well as slow closing irrespective of spring charge position.

Operation counter and mechanically operated indicator to show whether the circuit breaker is open or closed shall be provided on the circuit breaker operating mechanism.

All manually operating gear shall be so designed that the circuit breaker can be operated by one movement. The mechanism shall be such that the tripping spring can be charged while the circuit breaker is closed and the closing mechanism when charged shall not be operated by vibration caused by the circuit breaker opening under fault conditions.

The mechanism shall be designed for electrical control from remote. Local manual close/trip (lever/button) shall be provided in the mechanism box only.

No mechanical /electrical inter lock shall be inbuilt the manual spring charging of breaker.

Mechanical components other than spring charging mechanism link linkages shaft etc. shall have minimum plating thickness of 10-15 microns. The surface finishing ensures zinc plating trivalent passivation (ROHS compliance) and should withstand for salt spray test in artificial atmosphere upto 192 hours without white rust.

All fasteners exposed to Air should be of hot dip galvanized of MS 8.8 Grade for M10 and above and below M10 grade shall be of stainless steel.

The maximum power required for closing coil and shunt trip coil should not be more than 200 watts.

1.5 CONTROL CUBICLE (MECHANISM BOX)

A common control cubicle shall be furnished to house electricals, controls, monitoring devices and all other accessories except those which must be located on individual poles.

The cubicle shall have protection as per IS-13947 PT-1 equivalent to IP-55 protection (IS-2147) of gasketed weather proof construction, fabricated from sheet steel minimum 2.5mm thick.

The cubicle shall have front access door with lock and keys, and removable gland plate at the bottom for cable entry.

Additional locking arrangement (pad locking facility) is to be provided

1.6 WIRING & TERMINAL BLOCKS :

1.6.1 WIRING

Wiring shall be complete in all respects to ensure proper functioning of the control, protection, monitoring and interlocking schemes.

Wiring shall be done with flexible 1100V grade, PVC insulated switch board wires with 2.5 sq.mm. stranded copper conductor.

CT wiring.. TB must be connected / disconnected type of ledger type 12 way and control wiring terminal ledger must be 16A open type.

All CT wiring must be done with 2.5mm/ 4 mm dia ring type lugs only.

Each wire shall be identified at both ends with permanent markers bearing wire numbers as per wiring diagram. The wiring schematic may conform to relevant standards.

Wire termination shall be done with crimping type connectors with insulating sleeves. Wire shall not be spliced between terminals.

All spare contacts of relays, push buttons, auxiliary switchers etc. shall be wired upto terminal blocks in the control cubicle.

1.6.2. TERMINAL BLOCKS :

Terminal blocks shall be **1100 V** grade, box clamp type (Nut & Bolt Type).

Not more than two wires shall be connected to any terminal. Spare terminals equal in number to 20% active terminals shall be furnished.

Terminal blocks shall be located to allow easy access. Wiring shall be so arranged that individual wires of an external cable can be connected to constructive terminals.

For CTPT – disconnected type terminal blocks are required.

1.7 NAME/RATING PLATE:

BREAKERS : Each circuit-breaker shall be provided with a name plate or plates legibly and indelibly marked with atleast the following information:

- a) Name of manufacturer.
- b) Type of designation and serial number.
- c) Rated Voltage and current.
- d) Rated frequency.
- e) Rated symmetrical breaking capacity.
- f) Rated making capacity and
- g) Rated short-time current and its duration.
- h) P.O.No. with Date
- i) Period of guarantee

Note : 1. The word “Rated” need not appear on the name plate, recognised abbreviations may be used to express the above quantities.

2. When the circuit breaker is fitted with closing and/or tripping devices necessitating any auxiliary supply the nature of the auxiliary supply shall be stated either on the circuit breaker name-plate or in any other acceptable position.

3. The purchase order No. and date and year of supply and the words APEPDCL must be etched on the name plate.

CONTROL & RELAY PANELS :

2.1 CONSTRUCTION :

The Control panels to house meters, relays and other items as specified in clause VI(3) shall be weather proof and vermin proof and of rust-free pressed steel cubicle type with hinged door and locking device. Ventilation louvers shall be provided with GI mech. The frame shall be made of angle iron or structural steel of sufficient weight and strength to ensure alignment. The control panel shall be provided with inter connections, small wiring leads, terminal bolts, fuses, earth bar, multi core cable glands, earth connections etc, The panel should be provided with locking handle with built-in door lock and lock shall be provided with duplicate keys.

The outdoor panels shall be preferable of the following dimensions :-

Height	1750 mm
Width	800 mm
Depth	650 mm

The exterior of the panels shall be painted with dark admiral grey colour and interior should be painted with half white colour. The panel shall be provided with fuse units/MCBs for AC Circuit (both phase and neutral) for all phases of potential Circuit (Potential coil

connections to energy meters etc.) DC Control Circuit etc. The internal wiring of the panels shall be with 2.5 sq.mm 650 V grade standard copper PVC Insulated wiring of reputed make.

The Gauge of the sheet steel for the front of the panels (where the meters etc. are fixed) and supporting members of the panels shall be of 3 mm thick and for the other members of the panel sheet steel thickness shall be 2 mm.

Wherever control panels are fixed to the breaker structure necessary clearance from the ground to read the meters and to operate the switches shall be maintained. The suitable interconnection cable from breaker terminal, CTs terminal to control relay panel is 2.5 Sq.mm. PVC copper control cable (un-armored) shall be provided.

2.2 PAINTING:

Before painting all non-galvanised parts shall be completely cleaned and made free of rust, scale and grease and all external rough surface cavities on casting shall be filled by metal deposition. It shall be ensured that Phosphate coating is done by a suitable process on both the external and internal surfaces. The painting to be done on surface shall be by powder coating process

The interior parts and internal structural steel work shall be cleaned of all scale and rust by sand blasting or other approved method.

All metal enclosures shall be treated in 7 tank Pre-treatment process & should be painted with UV Resistant Pure Polyester Powder coating. The powder coated sheet steel fabrication shall fulfill 700Hrs of Salt spray test. The thickness of Painting/Powder coating shall be of 70-90 microns to withstand tropical heat and extremes of weather. The paint shall be guaranteed for 5 years from the date of receipt of material. (OR) Painting should be done with epoxy powder coating.

CURRENT TRANSFORMERS :

3.1 CONSTRUCTION

The core shall be high grade non-ageing electrical silicon-laminated steel of low hysteresis loss and high permeability to ensure high accuracy, at both normal and over current/voltage.

The secondary terminals shall be brought into a compartment on one side of current transformer for easy access. The Secondary terminal shall be provided with short circuiting arrangements of current Transformer. The secondary taps shall be adequately reinforced to withstand normal handling, without damage.

The current transformers shall be suitable for mounting on steel structures or concrete pedestals. The necessary flanges, bolts, etc, for the base of the Current Transformer shall be supplied and these shall be galvanized. The current transformer tank and other metal parts shall be galvanized.

All windings of Current Transformers shall be made of high grade electrolytic copper wire double paper covering insulation and the manufacturing of the units shall be done in completely closed and air-conditioned room. Fibre glass insulation sleeves are to be provided for primary winding. Details of winding and core shall be furnished.

The Current Transformers shall be complete in all respects with filling of oil conforming to IS:335 and with oil level indicator with minimum/maximum oil levels. The top cover and terminal box cover should be such that rain water does not enter even through the gaskets.

The cover of the CT should be designed to avoid the stagnation of water. The creepage distance should be **as per Latest IS.**

The minimum clearance required between poles in air required should be **as per Latest IS.**

Note : Facility for selecting the CT ratio in the control panel by closing the appropriate links in the Control and Relay Panel shall be provided. In no case changing of CT ratio with primary links shall be provided.

3.2. PRIMARY & SECONDARY TERMINALS: Primary terminals of Current Transformers to which the line connections are to be made shall have dimensions as per IS: 10601:1983 and material shall be of tinned cooper.

The secondary terminals shall be brought out into suitable compartment, which shall have a removable cover. The terminal box with the cover closed and tightened and the cable/conduit in position when supplied shall have a degree of protection conforming to IP 54 of IS: 2147. The secondary terminals will be M6 tinned brass studs.

3.3. TERMINAL AND EARTH CONNECTORS: Terminal connectors suitable for Panther ACSR Conductor shall be supplied. Suitable earth connectors for earthing connections shall also be supplied.

Thickness of the clamp must be minimum of 12mm and the stud clamp will be bimetallic.

3.4. EARTHING: The assembly comprising of the chassis, frame work and the fixed parts of the metal casing of the CT, shall be provided with two separate earthing terminals. The earthing terminals shall be adequate size protected against corrosion and metallicly clean and identified by means of the sign marked in a legible and indelible manner on or adjacent to the terminals.

3.5. SEALING ARRANGEMENT: Provision for sealing secondary terminal compartment, primary ratio change strips (if any) and tank effectively shall be made such that no fraud etc. such as tampering of the ratio or circuit (current) is possible. The holes provided for the above sealing provision shall be of adequate size and pass the sealing wire of about 14 SWG.

3.6. Each instrument Transformer shall be provided with prismatic type oil sight window at suitable location so that the oil level is clearly visible with naked eye to an observer standing at ground level.

3.7. For compensation of variation in volume of the oil due to temperature variation nitrogen cushion or stainless steel bellows shall be sued. Rubber diaphragms shall not be permitted for this purpose.

3.8. The units shall be vacuum filled with oil, after processing and thereafter hermetically sealed to eliminate air and moisture from entering the tank.

3.9 NAME/RATING PLATE :

Each Current Transformer shall have the following particulars indelibly marked on it or on a label permanently secure to it or its casing.

- a) Manufacturer's Name :
- b) Manufacturer's Sl.No. and /or type of designation:
- c) Rated transformation ratio :
- d) Rated Frequency
- e) Highest system voltage
- f) Insulation level and
- g) Rated short time thermal current with the associated rate time and rated dynamic current.

The Purchase Order No. and date and year of supply and the words "APEPDCL" must be etched on the name plate.

VI. SCHEDULE OF EQUIPMENT

1. CIRCUIT BREAKERS :

Vacuum Circuit Breaker complete with suitable painted steel support structure (with anchor bolts & nuts) for mounting 1 No. circuit breaker – 3 poles. Mechanism box, control and relay panel and Current Transformers.

- Note :
1. Earth strips as per IS shall be provided for proper earthing of equipments.
 2. Earth bar of copper (suitable for termination of 2 nos. 40 * 6 mm flats) shall be provided on circuit breaker support structure.
 3. Connecting Cable from Breaker to Control panel and Breaker to CTs are to be provided.
 - 3 (i) Connecting Cable from Breaker to CTs 6 Core cable of 5 mtrs length from each CT i.e., total 3 x 5 = 15 mtrs / Breaker and from Breaker to Control panel 10 core cable of 15 mtrs length.
 - 3 (iii) Size of interconnection cable from breaker terminal, CTs terminal to control relay panel is 2.5 Sq.mm. PVC copper control cable (un-armored).
 2. MECHANISM BOX CONTAINING :
 - a) Operating mechanism
 - b) Mechanical indicator for "ON" and "OFF" coupled to the Circuit breaker operating mechanism.
 - c) Mechanical close and trip (with protective flap) lever/push button.
 - d) Terminal blocks for control wiring and a spare terminal block (with 20% of the active terminals).
 - e) Operation Counter.
 - f) Operating handle for manual charging of springs and for slow closing.
 - g) 2 Nos. cable glands over and above those provided for control cables with suitable dummies.
 - h) Not less than 6 numbers normally open and 6 normally lose spare auxiliary contacts over and above those required for normal operation.

- i) 230 V single phase AC Motor/Manual operated spring charging mechanism complete with electrical spring release coil, 2 Nos. shunt trip coil and 1 No. closing coil.
- j) Local – Remote selector switch.
- k) Earth bar (suitable for termination of 2 Nos. 50 x 6 mm class)
- l) 6 Nos. Terminal connectors suitable for panther conductor for incoming and outgoing connector for outdoor VCB.
- m) Set of 2 pole MCBs for AC and DC supply with different colours.
- n) 1 No. of reputed make anti-pumping relay.

If offered breaker is with anti pumping mechanism plug in relay is also acceptable.

- o) TNC Switch heavy duty piston grip type

3. **CONTROL AND RELAY PANEL :**

Weather proof vermin proof control and relay panel shall be either structure mounted / floor mounted having equipped as follows :

- a) 3 ½ Digit LED Display CT operated digital A.C. Ammeter with Class of Accuracy 0.5 to suit the CT ranges indicated in Section-IV Schedule of materials. (110V AC Auxiliary supply).
One ammeter selector switch with “R”, “Y”, “B”, “N eutral” and “OFF” position size (96x96) mm.
- b) One Heavy duty Piston grip type Control Switch for VCB trip/Neutral/Close positions with spring return to neutral position.
- c) One Red and one Green pilot LED lamps for indicating close and open positions respectively.
- d) One Yellow LED lamp for healthy trip indication with push button control.
- e) One white LED lamp for spring charged indication.
- f) One amber LED Lamp for auto-trip indication.
- g) Numeric Relays shall be of reputed make (drawn out type) with the following features.
 - a) IDMT relay with three poles arranged for O/L and one pole for E/L for 33 KV Circuit Breakers.
- h) Two Nos. cable glands over and above those provided for control CT, PT, Control Circuit cables and auxiliary supplies (AC&DC) with suitable dummies.
- i) 3 ½ Digit LED Display digital A.C. Voltmeter with 7 positions switches with RY-YB-BR-RN-YN-BN-OFF selector switch with size 96x96 Sq.mm

- k) One 3 Phase Mw meter and one 3 phase MVAR Meter to work on 110V AC 50 Hz 1 Amp and scaled to suit the ranges of CTs. (Size (144x144) mm)
- a) One set alarm bell and push button for acceptance of alarm. Audio alarms shall be static hooters of reputed make. Voltage rating shall be 24V DC
- l) Necessary LT Fuses/MCBs for Control Circuit. Set of fine wiring with ferrules with standard code number of respective terminals and with suitable terminal connectors.
- m) 250 V three pin socket with plug & switch.
- n) Test terminal block with CT and PT terminals with links for testing ammeter and energy meter.(4W)
- o) Master trip relay of self reset type (fast acting)
- p) Trip circuit supervision & DC fail supervision relays are required.
- q) Stud terminal blocks (Bolt and nut type) for CT and PT control cables suitably wired with 6 Nos. spare terminals.
- r) One suitable copper earth strip of 12 x 3 mm size with adequate number of holes with suitable nuts and bolts.
- s) Suitable Space for fixing of feeder modem shall be provided. Cutout details shall be as per standard modems.
- t) Provision for space for fixing of HT TVR Meter shall be provided and Dimensions of Cutout dimensions suitable for fixing L&T or Secure or HPL Type TVMs of 135mm(L)x25mm(W) size and TTB Wiring

NOTE : 1. All the instruments and relays to be provided on control panel shall be flush mounted unless otherwise specified. The relays are to be worked on 1 amp secondary current of CTs and with DC Voltage of 24 V

2. All the indicating meters (Ammeter, Voltmeter, MW meter, MVAR meter) shall be of 144 x 144 or standard size and preferable of reputed make.

- s) 1 No. LED for TC1, through TS Relay, 1 No. LED for TC2 through TS relay.
- t) 1 No. plug point with switch (10A, 230 VAC)
- u) 1 No. Illuminator lamp with switch (40W, 230 VAC)
- v) 1 No. panel space heater with heater switch thermostat.

4. CURRENT TRANSFORMERS.

Three numbers outdoor CTs as specified.

- 5. Terminals connectors suitable for zebra ACSR conductor for 33 KV and panther ACSR conductor for 11KV shall be supplied for Circuit Breaker (6 Nos.) and CT terminals (6 Nos.)

Suitable inter connection between circuit breaker terminals and CT terminals are to be provided.

Cables from circuit breaker and CTs to control panel shall be provided. As specified in the Section VI Schedule of equipment.

Note : Other standard accessories which are not specifically mentioned but supplied with breakers of similar type and rating for efficient and trouble free operation shall be provided.

VII. TESTS :

The Circuit breakers and current transformers shall be subjected to the following routine and type tests in accordance with the details specified in the relevant Indian Standards as amended from time to time or any other equivalent international standards.

1. CIRCUIT BREAKER : IS 13118/IEC 62271-100/2008 Latest version.

Copy of type test certificates shall be enclosed to the tender. The date of type test certificates shall not be later than 5 years as on date of bid opening.

ROUTINE TESTS :

- a) Measurement of resistance of the main circuits.
- b) Operation tests.
- c) One minute power frequency voltage dry withstand test on the circuit breakers.
- d) One minute power frequency voltage dry withstand test on auxiliary circuits.

1.2 TYPE TESTS : Shall be done as per IS/IEC

- a) Temperature rise test for the main circuits.
- b) Measurement of resistance of the main circuit.
- c) Operation tests.
- d) Mechanical endurance tests (M2 class suitable for 10000 operations).
- e) Impulse voltage tests.
- f) One minute power frequency voltage dry withstand tests.
- g) One minute power frequency voltage wet withstand tests.
- h) Tests for short circuit conditions.
- i) Tests for short time current.
- j) Seismic switching duty test
- k) Capacitor switching duty test.

1.3 ACCEPTANCE TESTS :

The inspecting officer shall carryout acceptance test on 10% of circuit breakers, randomly chosen from the offered lot.

The acceptance tests shall be as follows:

- a) Measurement of resistance of main circuit.
- b) Operation test. This shall comprise five operation test cycles.
- c) One minute power frequency voltage dry withstand test on the circuit breaker.
- d) One minute power frequency dry withstand test on Auxiliary circuit.

The method of carrying out the above acceptance tests shall be as per IS : 13118/1991. Test parameters wherever applicable shall be as per this IS.

2. CURRENT TRANSFORMERS:

- 2.1. The following Type tests as per IS 2705 (Latest version) shall be conducted and Type Test Certificates for the tests shall be enclosed along with the tender. The date of type tests shall not be later than 5 years as on date of bid opening.

Short time current Test.

- a) Temperature rise test.
- b) Lightning Impulse Test.
- c) High Voltage Power frequency wet withstand voltage test.
- d) Determination of errors or other characteristics according to the requirements of the appropriate designation or accuracy class.

Note: Satisfactory Valid type test certificates from Central Govt. /NABL International labs is to be furnished for the tests mentioned above as per the specification along with tender bid. Type tests applicable as per IS:13118 or IEC – 6227 1-100. The bid without required type test certificates, the offer shall be treated as non-responsive. Provisional/in house type testing reports are not acceptable.

2.2 ACCEPTANCE & ROUTINE TESTS: The following tests shall be conducted as per IS:2705: 1992.

- a) Verification of terminal marking and polarity.
- b) Power frequency dry withstand Test on primary & secondary windings.
- c) Over Voltage Interturn test.
- d) Determination of errors or other characteristics according to the requirements of the appropriate designation or accuracy class.

VIII SPECIAL GUARANTEE FOR CIRCUIT BREAKERS :

- i) The Circuit Breakers (total equipment) shall be guaranteed for satisfactory operation for a period of 5 years from the date of receipt at stores.

IX. DRAWING AND LITERATURE :

Drawings and technical literature of Breakers, Current Transformers and panels shall be enclosed to the offer, Tenders not accompanied by the above are liable to be rejected. These drawings and literature are to be supplied in duplicate copies along with each unit in the event of order and are to be housed in a proper weather proof enclosure on the rear of the control panel door. One set of reproducible drawings shall be supplied. Schematic wiring diagrams of the control circuits of the circuit breaker and control & relay panel shall be displayed (embossed on a plate/Laminated) on the doors of the circuit breaker, control cubicle and control & relay panel respectively.

X. OVERALL DIMENSIONS AND FOUNDATION DETAILS:

The manufacturer shall give the necessary information as regards the overall dimensions of the circuit breaker and foundation details.

XI. PACKING :

All the equipments shall be packed in suitable crates with suitable steel bands so as to withstand rough handling and storage at destination.

XII. SPARE PARTS:

A list of recommended spares including vacuum interrupters may be indicated for operation of each type breaker along with their prices.

GUARANTEED TECHNICAL PARTICULARS FOR CIRCUIT BREAKERS 33 KV

ii) RATED VALUES AND CHARACTERISTICS :

No. of Poles

Manufacturer's Type & Designation

Rated Voltage

Rated Insulation-Level.

Impulse withstand voltage

One minute Power frequency withstand voltage.

One minute Power frequency withstand voltage on Auxiliary wiring.

Rated Frequency.

Rated Normal Current

Rated Cable charging current

Rated (Single) Capacitor breaking current

Rated Small Inductive breaking current

Rated Symmetrical Short Circuit breaking Current and breaking capacity in MVA.

Rated Transient Recovery Voltage.

Rated short Circuit making current

Rated Operating Sequence

Rated duration of short circuit

Opening time and Break time (milli Sec.)

Closing Time (Milli Sec.)

iii) Whether type test Certificate enclosed with the Tender.

Y. weight of complete Circuit Breaker :

Z. i) Pressure maintained in vacuum chamber.

Gap between the contacts in Vacuum.

Area of contacts.

1 The voltage to which the circuit breaker shall be capable of withstanding indefinitely across open contacts.

ii) Minimum Clearance in

air i) Between Poles

ii) Between Live parts to earth

iv) OPERATING MECHANISM OF CIRCUIT BREAKER AND ASSOCIATED EQUIPMENT :

Type of closing mechanism.

Whether Circuit breaker is Fixed trip or Trip free.

No. and type of auxiliary contacts (No. of spare normally open contacts and No. of spare normally closed contacts are to be indicated).

Power requirement :

Closing coil

Opening coil

Electrical service life :

Rated Current (times)

Rated interruption current (times)

Periodicity of maintenance for the following : For maintaining Vacuum in interrupting chamber.

- 1 For maintaining Vacuum in interrupting chamber.
- 2 For changing contacts.
- 3 Other maintenance schedules if any.

6. GUARANTEED TECHNICAL PARTICULARS FOR CURRENT TRANSFORMERS

33 KV

400-200-100/1-1A

- 1) Type
 - 2) Manufacturer's Type & designation
 - II. Rated Voltage
 - JJ. Rated Primary current
 - KK. Rated secondary current Core I
Core II
 - LL. No. of cores (Secondary core details)
 - MM. Rated Output in VA
Core I Core II
Class of accuracy
Core I
Core II
 - NN. Accuracy Limiting factor
Core I
Core II
 - OO. Method of ratio change and secondary connection details & connection diagram.
 - PP. Secondary voltage
Core I
Core II
 - QQ. Secondary Limiting Voltage
Core I
Core II
-
1. One second short time current
 2. Rated current dynamic (Peak value)
 3. Rated continuous thermal current temp. rise over ambient.
 4. One minute power frequency Dry/ Wet withstand voltage in KV (r.m.s.)
 5. 1/50 micro sec. Impulse withstand test voltage in KV (Peak)
 6. One minute power frequency withstand test voltage on secondaries in KV (r.m.s.)
 7. Weight of Oil in Kg.
 8. Total weight in Kg.
 9. Magnetisation curve of CT core.
 10. Mounting details
 11. Overall dimensions.

III. GUARANTEED TECHNICAL PARTICULARS for 3 O/C + 1E/F NUMERICAL NON DIRECTIONAL IDMT (WITH HIGHSET) RELAYS :-

CT Input Rating	-	1A /5A Dual rated
Frequency	-	50 Hz
DC Auxiliary Supply	-	18V to 220VDC
Protection Settings		
Phase Fault	-	5% to 200% (in step of 1%)
Earth Fault	-	5% to 80%(in step of 1%)
High set Phase fault	-	50% to 2000%(in step of 5%)
High set Earth Fault	-	50% to 800%(in step of 5%)
P/F Time Multiplier(IDMTL)	-	0.01 to 1.0sec(in step of 0.001sec)
E/F Time Multiplier(IDMTL)	-	0.01 to 1.5sec(in step of 0.001sec)
P/F DTL	-	0.1 to 100 sec (in Step of 0.01sec)
E/F DTL	-	0.1 sec to 100sec (in Step of 0.01sec)
P/F Highset DTL	-	0.1sec to 100sec (in Step of 0.01sec)
E/F Highset DTL	-	0.1sec to 100sec (in Step of 0.01sec)
Reset Time	-	0 Sec to 100 Sec
Curve selection provision :- Normal Inverse 3 Sec , Normal Inverse 1.3 Sec, EI,VI,DT and LTL and IEEE2 curves		
Output Contacts The Relay has the following output contacts Common Trip and Alarm Relay outputs	-	2 N/O +1 N/C Programmable
Contact Rating Carry Continuously Breaking capacity Making capacity in Amps	-	Maximum 10Amps Maximum 240W Maximum 10A
LED indication		1.4 LEDs for O/L (R,Y &B) and E/L 2. 4 LEDs for High set O/L (R,Y &B) and High set E/L 3. 2 LEDs for Power On and Protection Healthy Indications 4. One LED for Error indication
Push Buttons		For programming
Password facility		Default as well as customer change Password Required and also restore factory settings is to be part of relay.

Communication		RS 232/RS 485 with 9 pin male D-Port of modbus protocol and front USB Port
Display:- Bright Alphanumeric LCD display for settings, readings and fault tripping data of minimum number 10 reports(with date and time stamping) The supplied relays shall be draw out type		
Measurements		L1,L2,L3 and Earth
Burden AC Current input 5 A Rating 1 A Rating	- -	$\leq 0.1\text{VA}$ $\leq 0.2\text{ VA}$
Environmental Temperature Operating range Storage range Humidity Transient Over voltage		As per IEC
Insulation 2.0 KV rms for 1 min between all terminal and earth 2.0 KV rms for 1 min between independent circuits 1.0 KV rms for 1 min across normally open contacts		As per IEC
High frequency Disturbance 2.5KV Common (Longitudinal) mode 1.0KV Series (Transverse) mode Electrostatic Discharge 6 KV Contact Discharge 8 KV Air Discharge		As per IEC
Radio Frequency Interference 20MHz to 1000MHz, 10 V/m		As per IEC
Fast Transient 2KV 5/50ns, 2.5kHz repetitive Vibration (Sinusoidal) Shock and Bump		As per IEC
Mechanical Classification Durability		As per IEC
The relays shall have facility of minimum 10 Nos. fault tripping data such as 1.fault magnitude 2.Date and time of occurrence 3.Flag indication <ol style="list-style-type: none"> Disturbance Recording facility DC Healthy Facility for two setting groups depending upon the status of BI shall be provided. Note :- The supplier shall give one copy of relay software in form of CD/Pen drive		