

**TECHNICAL SPECIFICATIONS FOR LT UPTO (1100 V) 31/2 x 300 Sq.mm XLPE
INSULATED UNDERGROUND CABLES**

1.0 SCOPE:

1.1 The scope of this specification covers the design, manufacture inspection and testing the finished ISI marked LT, 1100 volts, 31/2 x 300 Sq.mm stranded, compact aluminum conductor, with XLPE insulated, PVC inner sheathed, galvanized steel strip armored and overall PVC sheathed Black colour cable conforming to IS:7098 /88 with latest amendments and as per specification detailed.

2.0 RATED VOLTAGE:

The rated voltage of the cable shall be 1100 Volts AC with the highest system voltage of 1100 Volts between phases of the effectively earthed three-phase transmission system.

The cables shall be capable of operating continuously under the system frequency variation of ± 3 Hz, voltage variation of $\pm 10\%$ and a combined frequency – voltage variation of $\pm 10\%$.

3.0 APPLICABLE STANDARDS:

Unless otherwise stipulated in the specifications, the latest version of the following Standards shall be applicable:

- a. IS 7098 (Part 2)-Cross-linked Polyethylene insulation for Cables.
- b. IS 8130-Conductors for insulated electrical cables and flexible cords.
- c. IS 10810(series)-Methods of tests for cables.
- d. IS 10418-Drums for electric cables.
- e. IS 3975-Specification for mild steel wires, strips and tapes for armouring of cables.
- f. IS 5831-Specification for PVC insulation sheath for electric cables.
- g. IS 10462-Fictitious calculation method for determination of dimensions of protective coverings of cables Part 1 - Elastomeric and thermoplastic insulated cables.

The cables manufactured to any other International Standards like BSS, IEC or equivalent standards not less stringent than Indian Standards are also acceptable. In such cases the Bidders shall enclose a copy of the equivalent international standard, in English language, along with the bid.

4.0 CONSTRUCTION:

4.1 Conductor: - The cable conductor shall be made from stranded aluminum to form compact sector shaped conductor having resistance within the limits specified in IS:8130/1984 and any amendment thereof. The wires shall be laid up together with a suitable right hand lay. Stranded Class 2 – as per the IS:8130 / IEC 60228/ BS 6360 standards.

4.2 Insulation: - The insulation shall be cross linked polyethylene applied by extrusion and shall be steam(wet) cured as per IS:7098(1)1988 and curing in hot water tank/bath is not accepted.:

<u>Sl.No.</u>	<u>Properties</u>	<u>Requirements</u>
1.	Tensile Strength	12.5N/mm ² , Min.
2.	Elongation to break	200 percent, Min
3.	Aging in air oven: a) Treatment: Temperature: Duration: b) Tensile Strength variation: c) Elongation variation:	135 \pm 3°C 7 days \pm 25 percent, Max \pm 25 percent, Max
4.	Hot set: a) Treatment: Temperature: Time under load Mechanical stress b) Elongation under load c) Permanent elongation (set) after cooling	200 \pm 3°C 15 min 20N/cm ² 175 percent, Max 15 percent, Max

5.	Shrinkage: a) Treatment: Temperature Duration b) Shrinkage	130±3°C 1 hour 4 percent, Max
6.	Water absorption (Gravimetric): a) Treatment: Temperature: Duration b) Water absorbed	85±2°C 14 days 1 mg/cm ² , Max
7.	Volume Resistivity a) at 27°C b) at 70°C	1x10 ¹⁴ ohm-cm, Min 1x10 ¹³ ohm-cm, Min
8	Thermal Resistivity	350 degrees C cm/W
9	Power factor at maximum conductor temperature	0.008
10	Dielectric strength	22 kV/mm

The XLPE insulation should be suitable for specified 1.1 KV system voltage.

The manufacturing process shall ensure that insulations shall be free from voids.

The insulation shall withstand mechanical and thermal stresses under steady state and transient operating conditions.

The insulation of the cable shall be high stranded quality, specified in IS:7098 (Part-II/1985). Withstand continuous conductor temperature of 90 deg C, which means higher continuous rated current carrying capacity.

The cables can operate even at conductor temperature of 130 deg C continuously and 250 deg C during a Short Circuit condition

4.3 SHEATH : The sheath shall be suitable to withstand the site conditions and the desired temperature. It should be of adequate thickness, consistent quality and free from all defects.

The PVC sheath shall be extruded as per IS:7098 (Part – I/1988). IEC:60502 Part– I, BS:6622, LSOH to BS:7835.

4.4 ARMOUR : Armoring shall be applied over the inner sheath with single galvanized steel complying with the requirements of IS:3975/1979. The dimensions of the galvanized strip shall be as specified in table 4 of the IS:7098/Part-I/1988. The armour wire shall be applied as closely as practicable. The direction of the lay of the armour shall be left hand. The joints in armour wire shall be made by brazing or welding and the surface irregularities shall be removed. A joint in any wire shall be atleast 300mm from the nearest joint in any other armour wire in the complete cable and shall be as per IS:7098 Part 1, IS: 3975.

4.5 OUTER SHEATH : Extruded PVC ST2, outer sheath as per IS:5831/1984, IS:7098 Part 1, IEC:60502 Part – 1, BS:6622, LSOH to BS:7835. shall be applied over armoring with suitable additives to prevent attack by rodents and termites. Outer sheathing shall be designed to offer high degree of mechanical protection and shall also be heat, oils, chemicals, abrasion and weather resistant. Common acids, alkalis, saline solutions etc., shall not have adverse effects on the PVC sheathing material used.

4.6 The cables should be suitable for use in solidly earthed system.

4.7 The power cables shall be manufactured to the highest quality, best workmanship with scientific material management and quality control. The bidder shall furnish the quality plan, giving in detail the quality control procedure / management system.

4.8 The cable shall be suitable for laying in covered trenches and/or buried underground to meet the outdoor application purposes.

5.0 The parameters of the LT power cables to be supplied shall be as specified below

Nom. cross sectional area (Sq.mm)	Nom. Thickness of XLPE insulation mm main core	Armoured			Max.DC conductor resistance at 20°C (ohm/km)	AC current rating	
		Nom. Steel Armour size(mm)	Approx. Overall dia. (mm)	Approx. weight (kg/km)		In air (amps)	In ground (amps)
25	0.90	4 X 0.8	22.8	821.0	1.200	95	97
35	0.90	4 X 0.8	24.9	961.0	0.868	117	116
50	1.00	4 X 0.8	28.1	1195.0	0.641	140	134
70	1.10	4 X 0.8	33.0	1569.0	0.443	176	167
95	1.10	4 X 0.8	35.8	1903.0	0.320	221	199
120	1.20	4 X 0.8	39.0	2303.0	0.253	258	227
150	1.40	4 X 0.8	42.9	2720.0	0.206	294	255
185	1.60	4 X 0.8	47.5	3276.0	0.164	339	287
240	1.70	4 X 0.8	52.7	4048.0	0.125	402	333
300	1.80	4 X 0.8	58.4	4872.0	0.100	461	375
400	2.00	4 X 0.8	65.6	6101.0	0.0778	542	426

6.0 The short circuit current of the LT cable to be as specified below

Sq.mm of LT Cable	Short Circuit Current(KA)
25	2.420
35	3.370
50	4.790
70	6.680
95	9.030
120	11.400
150	14.200
185	17.500
240	22.600
300	28.200
400	37.600

7.0 SYSTEM DETAILS:

General Technical particulars

Nominal system voltage (rms) (U)	0.44KV
Highest system voltage (rms) (U _m)	1.1 KV
Number of Phase	3
Frequency	50Hz
Variation in Frequency	+/- 3%
Type of Earthing	Solidly Earthed
Total relay & circuit breaker Operating time	15 – 20 cycles

8.0 CLIMATIC CONDITIONS:

(a)	Maximum ambient air temperature (in shade)	45 ⁰ C
(b)	Maximum ambient air temperature (under sun)	50 ⁰ C
(c)	Maximum daily average ambient air temperature	35 ⁰ C
(d)	Maximum yearly average ambient air temperature	30 ⁰ C
(e)	Maximum humidity	100%
(f)	Altitude above M.S.L.	Up to 1000M
(g)	Average No. of thunder storm days per annum	50
(h)	Average No. of dust storm days per annum	Occasional
(i)	Average No. of rainy days / annum	90
(j)	Average Annual Rain fall	925mm
(k)	Normal tropical monsoon period	4 months

9.0 DESIGN CRITERIA:

The cables that are covered in these specifications are intended for use outdoor , under the climatic conditions and installation conditions described in the technical specification.

Any technical feature, not specifically mentioned here, but is necessary, for the good performance of the product, shall be incorporated in the design. Such features shall be clearly brought out under Technical deviations schedule only, in the offer made by the bidder, giving technical reasons, and justifying the need to incorporate these features.

For continuous operation of the cables, at specified rating, the maximum conductor temperature shall be limited to the permissible value as per the relevant standard, generally not exceeding 90°C under normal operation and 250°C under short – circuit conditions.

The cables in service will be subject to daily load cycles, of two peaks during a day; morning peak and evening peak, with around 25% to 50% loading during the nights.

The materials used for outer sheaths shall be resistant to oils, acids and alkalis.

The cables shall have the mechanical strength required, during handling and laying.

The cables shall be designed to withstand the thermo-mechanical forces and electrical stresses during normal operation and transient conditions.

The cables shall be designed to have a minimum useful life span of Thirty-five years.

The detailed design drawings shall be submitted along with the bid documents.

10.0 MANUFACTURE PROCESS:

Cross-linking of the insulation materials (pre compounded polyethylene) shall be conforming to IS: 7098 (Part – II) and the proof of purchase of the above insulating material shall be submitted and is to be offered for stage inspection..

11.0 MATERIALS:

11.1 **Conductor:** -The conductor shall be of stranded construction. The material for conductor shall consist of the plain aluminum of H2 or H4 grade as per clause – 3 of IS 8130/ 1984.

11.2 The minimum number of wires shall be 53 for circular compacted 400 sq. mm aluminum conductor as per table – 2 of IS 8130/ 1984.

12.0 CORE IDENTIFICATION:

12.1 The core identification for 31/2 core cables shall be provided, by suitable means, like, by application of individual colour or colored stripes, or by numerals or by printing on the cores as per clause 13 of IS: 7098 - Part 2

12.2 For identification of different coloring of XLPE Insulation, or by using colored strips, red, yellow and blue colors respectively shall be used to identify the phase conductors.

13.0 LAYING UP OF CORES:

The cores shall be laid together with a suitable right hand lay. The interstices at the center shall be filled with a non- hygroscopic material.

14.0 INNER SHEATH (COMMON COVERING):

The laid up cores shall be provided with inner sheath applied either by extrusion . It shall be ensured that the shape is as circular as possible. The inner sheath shall be so applied that it fits closely on the laid up cores and it shall be possible to remove it without damage to the insulation.

14.1 The thickness of the inner sheath (common covering) shall be given as follows:

CALCULATED DIAMETER IN MM OVER LAID UP CORES [REF IS 10462 (PART 1)]		THICKNESS OF INNER SHEATH (Min) mm
Over	Up to and including	

–	25	0.3
25	35	0.4
35	45	0.5
45	55	0.6
55	–	0.7

14.2 When one or more layers of binder tapes are applied over the laid up cores, the thickness of such tapes shall not be construed as a part of inner sheath.

15.0 ARMOURING:

Armouring shall be single strip steel wire applied over the inner sheath as closely as practicable. The direction of the lay of the armour shall be left hand.

The armour shall consist of galvanized strip steel The dimensions of the galvanized steel wires shall be 4 X 0.8 mm (Nominal)

The joints in the armour strip shall be made by brazing or welding and the surface irregularities shall be removed. A joint in the wire shall be at least 300-mm from the nearest joint in any other wire in the complete cable.

Bidders shall furnish the calculation / data sheet for the short circuit carrying capability of the Armour.

16.0 OUTER SHEATH:

The outer sheath shall be applied by extrusion. It shall be applied over the armouring shall consist of poly-vinyl chloride (PVC) compound, conforming to the requirements of type ST-2 of IS 5831. Suitable additives shall be added to give anti termite protection.

The minimum thickness of the PVC outer sheath shall be as per IS:10462 and as detailed.

Calculated diameter under the outer sheath [IS 10462 Part 1] – mm		Nominal thickness of the outer sheath (ts) - mm
Over	Up to and including	
–	15	1.24
15	25	1.40
25	35	1.56
35	40	1.72
40	45	1.88
45	50	2.04
50	55	2.20
55	60	2.36
60	65	2.52
65	70	2.68
70	75	2.84
75	–	3.0

IDENTIFICATION:

The outer sheath shall have the following information embossed or indented on it; the manufacturer's name or trade mark, the voltage grade, the year of manufacture and the letters "AP_PDCL". The identification shall repeat every 300/350mm along the length of the cable. Outer sheath of cable shall be black in permanent colour.

17.0 INSPECTION AND QUALITY CONTROL:

The Bidder shall furnish a complete and detailed quality plan for the manufacturing process of the cable. All raw materials shall conform to relevant applicable standards and tested for compliance to quality and requirement. During the manufacturing process, at all stages, inspections shall be made to check the physical and dimensional parameters, for verification to compliance to the standards. The bidder shall arrange, for inspection by the purchaser, during manufacture with one month advance notice for verifying the various stage inspections as specified in the quality assurance plan enclosed to verify the quality control process of the Bidder.

18.0 TYPE TESTS:

Type test certificates from Accredited NABL Testing Laboratories for 1.1 kV XLPE UG cable, shall be submitted along with Bid. The Type Tests should have been conducted not later than 5 years as on the date of BID opening.

Stage wise Inspection: The Bidder shall offer the stage wise inspection as detailed in the quality assurance plan

Notwithstanding, that type test have been conducted earlier, the supplier shall conduct all type tests as per IS: 7098 part-1, 1989, with up to date amendments or equivalent international standard, and supplies made only after approval of test reports from the purchaser. The purchaser reserves the right to wave the repetition of the type test.

All acceptance tests shall be conducted in the presence of the purchaser/ representative.

The supplier shall give 15 days advance notice for inspections, and witnessing of tests by the purchaser or his representative.

The following type tests shall be conducted on the cable.

Sl. No.	Test	Requirement	Test method Ref Part no of IS: 10810
a)	Tests on conductor		
	i) Tensile test	IS:8130	2
	ii) Wrapping test	IS:8130	3
	iii) Resistance test	IS:8130	4
b)	Tests for armoured wires and strips	Clause 15.2 & IS:3975	36 to 42
c)	Test for thickness of insulation and sheath	Clause 4.3, 14.2 & 16.2	6
d)	Physical tests for insulation:	Clause 4.2	
	i) Tensile strength and elongation at break		7
	ii) Aging in air oven		11
	iii) Hot test		30
	iv) Shrinkage test		12
	v) Water absorption (gravimetric)		33
e)	Physical tests for outer sheath	IS: 5831	
	i) Tensile strength and elongation at break		7
	ii) Aging in air oven		11
	iii) Shrinkage test		12
	iv) Hot deformation		15
f)	High voltage test	Clause 22.7	45
g)	Flammability test	Clause 22.8	53

19.0 ACCEPTANCE TEST:

The sampling plan for acceptance test shall be as per IS 7098 part -II, Appendix 'A'.

The following shall constitute the acceptance test.

- Tensile test for aluminum.
- Wrapping test for aluminum.
- Conductor resistance test.
- Test for thickness of insulation.

- e) Test for thickness of inner and outer sheath.
- f) Hot-set test for insulation.
- g) Tensile strength and elongation at break test for insulation and outer sheath.
- h) High voltage test.
- i) Insulation resistance (volume resistivity) test.
- j) UV exposure test

20.0 ROUTINE TEST:

The following shall constitute routine tests:

- a) Conductor resistance test.
- b) High voltage test.

DETAILS OF TESTS:

Unless otherwise mentioned in this specification, the tests shall be carried out in accordance with appropriate part of IS: 10810.

High Voltage Test at room temperature:

The cables shall withstand a voltage of 3KV AC (rms) at a frequency of 40 to 60 Hz or an AC voltage of 7.2KV , between conductors and between conductors and ECC (if any) for a period of 5 minutes each test connection.

Flammability test: Period of burning after removal of the flame shall not exceed 60 seconds and the unaffected (uncharred) portion from the lower edge of the top clamp shall be at least 50-mm.

APEPDCL reserves the right to select a random sample of 1.1 kV UG cable from the Manufacturer's end which are ready to dispatch and also ongoing cable laying works and the same samples will be sent to any testing laboratory as desired by APEPDCL at Bidders cost. If the testing results are found to be not satisfactory APEPDCL reserves the right to reject the entire batch of cable received and insists for replacement of material free of cost. The decision of APEPDCL in this regard is final.

21.0 PACKING:

The cables, as per specified delivery lengths, shall be securely wound /packed in non- returnable wooden drums, capable of withstanding rough handling during transport by Rail, Road, etc. The packing should withstand storage conditions in open yards. The cable drums shall conform to IS 10418-1982 or equivalent standard. The dimensional drawings of wooden drums shall be furnished with the bid. The drum shall be provided with circumferential lagging of strong wooden planks. The end of the cable shall be sealed with good quality heat shrink sealing caps. The sufficiently required additional sealing caps shall be supplied for use of testing during laying and jointing at site and to seal spare lengths of cable. The packing should be able to withstand the rigorous of transport. The following information in bold letters in English shall be painted on the flanges.

- i) Name & Address of the manufacturer, Trade name/Trade mark/Brand
- ii) Size of cable (Cross section) rated voltage, standard, insulation, cable code, drum No., and year of manufacture.
- iii) Length of cables (Meters)
- iv) Direction of rolling

- v) Net weight (in Kg)
- vi) Gross weight (in Kg)
- vii) Owners purchase order reference.

22.0 SEALING OF CABLE ENDS ON DRUMS:

The cable ends shall be sealed properly so that ingress of moisture is completely prevented. The individual core endings shall be sealed effectively with water resistant compound applied over the core and provided with a heat shrinkable or push-on or Tapex or cold shrinkable type cap of sufficient length with adequate cushion space so that the conductor does not puncture the cap in case of movement of the core during unwinding or laying. Before sealing, the semi conducting layer on the cores may be removed for about 2 mm at each end, to facilitate checking the insulation resistance from one end, without removing the sealing cap at the other end.

The three cores should have an overall heat shrinkable or push-on or Tapex or cold shrinkable type cap with adequate end clearance, and sufficient cushioning to prevent puncturing of the overall sealing cap due to stretching of the cores. The sealing cap shall have sufficient mechanical strength and shall prevent ingress of moisture into the cable. The ends of single core cables shall also be sealed on the same lines to prevent entry of moisture.

23.0 CABLE LENGTHS:

The cables shall be supplied in continuous lengths of 500 m or more with 5% tolerance and cable shall on the wooden drums only.

24.0 QUANTITY TOLERANCE:

A +3% tolerance shall be allowed on the ordered quantity including 300-m cable as spare.

MARKING:

The packed cable drum shall carry the following information, clearly painted or stenciled.

- a) The letters AP-PDCL
- b) Reference to Standard and ISI mark.
- c) Manufacturer's Name or trade mark.
- d) Type of cable & voltage grade.
- e) Number of cores.
- f) Nominal cross-sectional area of conductor.
- g) Cable code.
- h) Length of cable on the drum.
- i) Direction of rotation.
- j) Gross weight.
- k) Country of Manufacture.
- l) Year of Manufacture.
- m) Purchase order and date.
- n) Address of consignee.

25.0 GUARANTEED TECHNICAL PARTICULARS:

The bidder, shall furnish the guaranteed technical particulars of the cable offered in the GTP format provided.

26.0 DRAWING & LITERATURE:

The following shall be furnished along with the tender

- a) Cross sectional drawings of the cables, giving dimensional details.
- b) An illustrated literature on the cable, giving technical information, on current ratings, cable constants, short circuit ratings, de rating factors for different types of installation, packing date, weights and other relevant information.

27.0. GUARANTEE: The cable manufactured shall be guaranteed for the period of 18 months from the date of receipt at stores.

28.0 The tenderer shall furnish a copy of valid BIS licence for ISI marking together with their offer, without which the offer shall be treated as non-responsive.

	Manufacturer's Name	
	Class of Power Cable	3½ c X 300 sq.mm
1	Name of the Manufacturer and country of origin	
2	Country of Manufacture	
3	Type of cable / cable code	
4	Applicable standard	
	Voltage	
5	a. Rated Nominal voltage	
	b) Rated Maximum voltage	
6	Suitability for :	
	a. Earthed system	
	Conductor	
	a) Nominal cross section (sq.mm)	
	b) Material	
7	c) Shape	
	d) Diameter of conductor (mm)	
	e) Number of wires per conductor (Nos.)	
	f) Nominal diameter of wire in conductor (mm)	
	Insulation XLPE	
	a) Curing process (furnish details separately)	
	b) Material/Composition	
8	c) Dia. over insulation	
	i. Nominal (mm)	
	ii. Average (mm)	
	iii. Minimum (mm)	
	Inner sheath	
	a) Type / composition	
9	b) Material	
	c) Tolerance on thickness	
	d) Diameter of cable over sheath (mm)	
	Armouring	
	a) Material	
10	b) Dia. of wire	
	Nom. (mm)	
	Min. (mm)	
	Outer sheath	
11	a) Type / composition	
	b) Material	
	c) Nominal thickness	

	Manufacturer's Name	
	Class of Power Cable	3½ c X 300 sq.mm
	d) Tolerance on thickness	
	e) Diameter of cable over sheath (mm)	
	Anti-termite treatment to outer sheath	
12	a) Material	
	External overall Dia. of cable	
	Short circuit rating of conductor 90 deg. C operating temperature for 1 Sec.	
13	Minimum cable bending radius (in terms of cable diameter)	
14	Permissible maximum tension	
15	Continuous current rating under specified insulation conditions at conductor temperature of 65 deg. C and 90 deg. C.	
16	Ground Temperature 30 deg. C	
17	Thermal resistivity of soil 150 deg. C CM/W	
18	Depth of laying 600 mm	
19	Ambient Air temperature 40 deg. C	
20	No. of circuits 1 OR 2	
21	Spacing between two circuits	
22	Formation	
23	Maximum permissible conductor temperature for continuous operation under specified installation conditions (deg. C)	
24	Conductor temperature at rated current (deg. C)	
25	Basic impulse level at conductor temperature of 90 deg. C (KV)	
26	Impulse wave shape	
27	Power frequency with stand voltage (KV)	
28	Tan Delta at 50 Hz (at U.KV and 90 (-5/+10) deg. C	
29	Sheath voltage at max. load	
30	Withstand voltage of sheath on spark test	
	Permissible short circuit current ratings of conductor	
31	i) 0.1 Sec KA	
	ii) 0.2 Sec KA	
	iii) 0.5 Sec KA	
	iv) 1.0 Sec KA	
	Conductor resistance DC & AC	
32	a) at 20 deg. C (d.c)/A.C. ohm/KM	
	b) at 90 deg. C (d.c)/A.C. ohm/KM	
	c) at 105 deg. C (d.c)/A.C. ohm/KM over load temp) a.c. (ohm)	
	Equivalent star resistance at 50 Hz of 3 phase current	
33	a) at 20 deg. C (d.c)/A.C. ohm/KM	
	b) at 90 deg. C (d.c)/A.C. ohm/KM	
	c) at 10% continuous overload temperature (ohm/KM)	
34	Star reactance at 50 Hz (ohm/KM)	
	Approximate impedance at 50 Hz per KM	

	Manufacturer's Name	
	Class of Power Cable	3½ c X 300 sq.mm
	a. at 20 deg. C ohm/KM	
	b. at 90 deg. C ohm/KM	
	c. at 10% continuous overload temperature (ohm/KM)	
35	Self electrostatic capacitance per phase (Micro farad/KM)	
	Maximum power factor at charging KVA of cables when laid direct in ground at normal voltage & frequency	
36	a) at ambient Temperature	
	b) at Maximum conductor Temperature	
	Impedance	
37	a) Positive and negative sequence impedance (ohm/KM)	37
	b) Zero sequence impedance (ohm/KM)	
	c) Zero sequence data	
	Series reactance / Resistance	
38	a) Series resistance (ohm/KM)	
	Series reactance (ohm/KM)	
	Shunt capacitive reactance (ohm/KM)	
39	Sheath resistance at 20 deg. C ohm/KM	
40	Surge impedance of cable (ohm/KM)	
	IR value at ambient temperature per KM	
	Maximum magnitude of partial discharge at 1.5 Uo	
	At Ambient Temperature (Po)	
	At High Temperature (Po)	
	Losses per Km.	
	NOTE : (i) Cable Conductor size 400 sq. mm	
	a) Total 3 phase dielectric loss	
41	i. One circuit alive Kw/KM	
	ii. Both circuits alive KW/KM on each circuit	
	b) Total 3 phase resistive loss	
	i. One circuit alive KW/KM	
	ii. Both circuits alive KW/KM on each circuit	
	c) Total 3 phase sheath / screen loss	
	i. One circuit alive KW/KM	
	ii. Both circuits alive load KW/KM on each circuit	
42	Other losses due to reinforcement	
43	One circuit alive KW/KM	
	Both circuits alive KW/KM on each circuit	
	Total losses	
44	i. One circuit alive KW/KM	
	ii. Both circuits alive KW/KM	
	Charging current at rated voltage per Km (Amps)	
45	Short circuit capacity of conductor for one second at 90 deg. C prior to short circuit and 250 deg. C during short circuit (KA)	
	Screening factor of cable for calculating interference on control and communication cables :	
46	Approximate value of attenuation of carrier current signals operating over a frequency range	

47	Manufacturer's Name	
	Class of Power Cable	3½ c X 300 sq.mm
	i. 50 KC/s- dB/KM	
	ii. 100 KC/s- dB/KM	
	iii. 150 KC/s- dB/KM	
	iv. 200 KC/s- dB/KM	
	Shipping weight and size of cable drum	
	a) Size of Drum	
	i. Dia. of Drum (M)	
	ii. Width of Drum (M)	
	iii. Gross Weight (Kgs)	
	iv. Length of cable per Drum(M)	
	v. Weight of Cable (Kg/M)	